

<b>Free Glycerin</b>	ASTM D 6584	Max 0.020 % mass
<b>Total Glycerin</b>	ASTM D 6584	Max 0.240 % mass
<b>Flash Point (Methanol)</b>	ASTM D 93	Min 130 °C (Max 0.2 % vol)
<b>Acid Number</b>	ASTM D 664	Max 0.50 mg KOH/g
<b>Water &amp; Sediment</b>	ASTM D 2709	Max 0.050 % vol
<b>Visual Appearance</b>	ASTM D 4176	Max 2 Haze rating
<b>Oxidative Stability</b>	EN 14112	Min 3.0 hr
<b>Sulfur</b>	ASTM D 5453	Max 15 ppm
<b>Cloud Point</b>	ASTM D 2500	Report °C
Kinematic Viscosity at 40 °C	ASTM D 445	1.9 – 6.0 mm <sup>2</sup> /sec
Sulfated Ash	ASTM D 874	Max 0.020 % mass
Copper Strip Corrosion	ASTM D 130	Max No. 3
Cetane Number	ASTM D 613	Min 47
Carbon Residue for 100% sample	ASTM D 4530	Max 0.050 % mass
Distillation, 90% recovered	ASTM D 1160	Max 360 °C
Phosphorous Content	ASTM D 4951	Max 0.001 % mass
Relative density at 60 °F	ASTM D 1298	Report
Na and K, combined	EN 14538	Max 5.0 ppm
Ca and Mg, combined	EN 14538	Max 5.0 ppm

